

STATE OF INDIANA

BEFORE THE TOWN COUNCIL OF SELLERSBURG, INDIANA

RESOLUTION NO. 2016 – R – 002

**A RESOLUTION AUTHORIZING SILVER CREEK WATER CORPORATION TO
SERVICE THE DEVELOPMENT OF TRADITIONS OF HUNTER STATION**

WHEREAS, this Town Council of Sellersburg, Indiana (“Council”) is the town legislative body of the town and the President of the town council is the town executive pursuant to Ind. Code § 36-5-2 *et seq.*; and,

WHEREAS, pursuant to Ind. Code § 36-5-2-9, the legislative body may adopt ordinances and resolutions for the performance of functions of the town; and,

WHEREAS, Silver Creek Water Corporation (“Silver Creek Water”) has requested a revision of their water system boundary line to allow Silver Creek Water to serve only the project known as Traditions of Hunter Station. (*See Exhibit “A”*); and,

WHEREAS, the Town’s Public Works Director has approved Silver Creek Water’s requests in that the Town’s current system does not meet the 1,000 gallon per minute at 20 psi requirement for fire flow for said development.

NOW, THEREFORE BE IT RESOLVED by this Town Council of Sellersburg, Indiana as follows:

1. That Silver Creek Water shall be authorized to service only the project known as Traditions of Hunter Station as indicated in Exhibit A.

This Resolution shall be in full force and effect after its adoption by the Town Council of Sellersburg, Indiana.

[Signature page to follow]



SILVER CREEK WATER CORPORATION

P O BOX 102 * 8104 COUNTY LINE ROAD
SELLERSBURG IN 47172-0102
812-246-2889 * FAX 812-246-6503

February 17, 2016

Paul Rhodes, President
Sellersburg Town Board
316 E. Utica Street
Sellersburg, IN 47172

RE: Traditions of Hunter Station

Dear Mr. Rhodes and Town Board,

We are requesting to revise our water system boundary line, to allow Silver Creek Water Corporation to serve only the project known as Traditions of Hunter Station. This is due to fire flow requirements for the development.

The existing boundary line between Silver Creek Water Corporation and the Town of Sellersburg Water Department, is considered to be the line between Plum Run and Hunter Station. Attached is a drawing of the area.

We have the required fire flow capacity to serve this development and would request immediate approval of adjusting our boundary line, so that we could begin the design process for them to connect to our system at Plum Run and Hunter Station.


Recent fire flow tests were conducted at Hunter Station, and your system at this location does not meet the 1,000 gallons per minute at 20 psi requirement for fire flow. Our system capacity tested at 1,664 gallons per minute at 20 psi.

Please call me at 812-246-2889 or email scott@silvercreekwater.org if you have any questions pertaining to this matter.

Sincerely,


Scott A. Ham
Manager


attachment




So Resolved this 14 day of March, 2016.

“Aye”


“Nay”


Paul J. Rhodes
Council President


Paul J. Rhodes
Council President


Brad Amos
Council Vice President


Brad Amos
Council Vice President


Martina Webster
Council Member


Martina Webster
Council Member


Jim LaMaster
Council Member

Jim LaMaster
Council Member


William Conlin
Council Member

William Conlin
Council Member


Attested by: Michelle Miller
Sellersburg Clerk-Treasurer